



NOTES:

1. IN RIGHT OF WAY AREAS, PLACE FH AT ROW LINE. HYDRANTS ARE NOT TO BE PLACED IN SIDEWALK AREAS OR WITHIN 6' OF A CURB. WHERE POSSIBLE, PLACE VALVE IN PAVEMENT. IF NOT POSSIBLE, PLACE A VALVE BOX PAD (DETAIL FROM CP WEBSITE) AROUND VALVE. NO VALVES ARE TO BE PLACED IN CONFLICT WITH PROPOSED/EXISTING CURBS OR GUTTERS.
2. FOR BURY DEPTHS GREATER THAN 5', ONE BARREL EXTENSION NOT EXCEEDING 2 FOOT IN LENGTH SHALL BE INSTALLED DIRECTLY BELOW THE FIRE HYDRANT.
3. ALL PIPE AND FITTINGS SHALL HAVE JOINT RESTRAINT FROM MAIN TO FIRE HYDRANT, ALL INCLUSIVE. THRUST BLOCKING SHALL BE CLASS A CONCRETE WITH A MINIMUM 1.5 SQUARE FOOT SURFACE AREA AGAINST PIPE. DO NOT BLOCK DRAIN HOLES.
4. CRUSHED STONE OR GRAVEL SHALL BE PLACED AROUND THE BOTTOM OF THE HYDRANT FOR A RADIUS OF AT LEAST 12" AND EXTEND AT LEAST 12" ABOVE THE OUTLET. DO NOT BLOCK DRAIN HOLES.
5. WELD SOCKET 2- $\frac{1}{2}$ " X 2" DEEP TO 1" SCH. 40 ROUND STEM EXTENSION, FITTED ON OPERATING NUT, SCH. 80 FOR LENGTHS OVER 10'.
6. VALVE EXTENSIONS ARE REQUIRED ON ALL VALVES THAT EXCEED 3' DEEP FROM FINISHED GRADE. VALVE EXTENSIONS SHALL BE PLACED SUCH THAT THE EXTENSION NUT IS BETWEEN 18" AND 24" FROM FINISHED GRADE.
7. VALVE SPECIFICATION PER CITY OF AUSTIN STANDARD SPECIFICATION ITEM NO. 511.

CITY OF CEDAR PARK

STANDARD FIRE HYDRANT INSTALLATION

ISSUED: JANUARY 28, 2005

THE ENGINEER ASSUMES RESPONSIBILITY
FOR APPROPRIATE USE OF THIS
STANDARD.